

## Suggested Specification

**System:** PVC Cellular Core (Foam Core) Pipe and PVC DWV Fitting System

**Scope:** This specification covers PVC cellular core (foam core) pipe and PVC DWV fittings used in sanitary drain, waste, and vent (DWV), sewer, and storm drainage applications. This system is intended for use in non-pressure applications where the operating temperature will not exceed 140°F.

**Specification:** Pipe shall be manufactured from virgin rigid PVC (polyvinyl chloride) vinyl compounds with a Cell Class of 11432 as identified in ASTM D 4396. Fittings shall be manufactured from virgin rigid PVC (polyvinyl chloride) vinyl compounds with a Cell Class of 12454 as identified in ASTM D 1784.

PVC cellular core pipe shall be Iron Pipe Size (IPS) conforming to ASTM F 891. PVC DWV fittings shall conform to ASTM D 2665. Pipe and fittings shall be manufactured as a system and be the product of one manufacturer. All pipe and fittings shall be manufactured in the United States. All systems shall utilize a separate waste and vent system. Pipe and fittings shall conform to NSF International Standard 14.

Installation shall comply with the latest installation instructions published by Charlotte Pipe and Foundry and shall conform to all applicable plumbing, fire, and building code requirements. Buried pipe shall be installed in accordance with ASTM D 2321 and ASTM F 1668. Solvent cement joints shall be made in a two step process with primer conforming to ASTM F 656 and solvent cement conforming to ASTM D 2564. The system shall be protected from chemical agents, fire stopping materials, thread sealant, plasticized vinyl products or other aggressive chemical agents not compatible with PVC compounds. Systems shall be hydrostatically tested after installation. **WARNING!** Never test with or transport/store compressed air or gas in PVC pipe or fittings.

**Referenced Standards:**

|                 |  |
|-----------------|--|
| ASTM D 4396     | Compounds for Cellular Core  |
| ASTM F 891      | Co-extruded PVC Pipe with Cellular Core                                    |
| ASTM D 2665     | PVC Drain, Waste, and Vent Fittings  |
| ASTM D 2564     | Solvent Cements for PVC Pipe and Fittings                                  |
| ASTM D 2321     | Underground Installation of Thermoplastic Pipe (non-pressure applications) |
| ASTM F 1668     | Procedures for Buried Plastic Pipe   |
| NSF Standard 14 | Plastic Piping Components and Related Materials                            |

Note: Latest revision of each standard applies.

(110)